

## Report

**Product:** AQUALIT COLOR T4450-xx BN00 / BW01

**Regarding:** RAL-GZ 430

Testing and evaluation of the release of dangerous substances

Determination of emissions into indoor air

**Report No:** 60671-A002-DGM-L

### Results:

Measurements after 28 days	Result BN00/BW01	requirement
TVOC C6-C16	62/65 µg/m <sup>3</sup>	</= 450 µg/m <sup>3</sup>
TVOC C16-C22	< 5 µg/m <sup>3</sup>	</= 100 µg/m <sup>3</sup>
CMR substances cat 1A/1B	< 1 µg/m <sup>3</sup>	< 1µg/m <sup>3</sup>
DMF (dimethylformamide)	< 1 µg/m <sup>3</sup>	<15 µg/m <sup>3</sup>
Formaldehyde	< 2 µg/m <sup>3</sup>	</= 60 µg/m <sup>3</sup>
R-value	0,01	</= 1
Odour measurement	1,8/1,9	</= 3,0