

## Report

**Product:** AQUALIT COLOR T450-10 BW01

**Regarding:** DIN EN 16516:2020-10  
Testing and evaluation of the release of dangerous substances  
Determination of emissions into indoor air

**Report No:** 57870-A002-DGM-L

**Results:**

Measurements after 28 days	result	requirement
TVOC C6-C16	230 µg/m <sup>3</sup>	</= 450 µg/m <sup>3</sup>
TVOC C16-C22	< 5 µg/m <sup>3</sup>	</= 100 µg/m <sup>3</sup>
CMR substances cat 1A/1B	< 1 µg/m <sup>3</sup>	< 1µg/m <sup>3</sup>
DMF (dimethylformamide)	< 1 µg/m <sup>3</sup>	<15 µg/m <sup>3</sup>
Formaldehyde	2 µg/m <sup>3</sup>	</= 60 µg/m <sup>3</sup>
R-value	0,07	</= 1
Odour measurement	1,6	</= 3,0