

### Report

**Product:** AQUALIT COLOR T450-30 BW01

**Regarding:** DIN EN 16516:2020-10  
Testing and evaluation of the release of dangerous substances  
Determination of emissions into indoor air

**Report No:** 57870-A004-DGM-L

**Results:**

| Measurements after 28 days | result                | requirement               |
|----------------------------|-----------------------|---------------------------|
| TVOC C6-C16                | 58 µg/m <sup>3</sup>  | </= 450 µg/m <sup>3</sup> |
| TVOC C16-C22               | < 5 µg/m <sup>3</sup> | </= 100 µg/m <sup>3</sup> |
| CMR substances cat 1A/1B   | < 1 µg/m <sup>3</sup> | < 1µg/m <sup>3</sup>      |
| DMF (dimethylformamide)    | < 1 µg/m <sup>3</sup> | <15 µg/m <sup>3</sup>     |
| Formaldehyde               | < 2 µg/m <sup>3</sup> | </= 60 µg/m <sup>3</sup>  |
| R-value                    | 0,02                  | </= 1                     |
| Odour measurement          | 1,4                   | </= 3,0                   |