

Report

Product: AQUALIT T260-xx in system built up with itself 2x

Regarding: DIN EN 16516:2020-10
Testing and evaluation of the release of dangerous substances
Determination of emissions into indoor air

Report No: 57542-A004-DGM-L

Results:

Measurements after 28 days	result	requirement
TVOC C6-C16	620 µg/m ³	</= 450 µg/m ³
TVOC C16-C22	< 5 µg/m ³	</= 100 µg/m ³
CMR substances cat 1A/1B	< 1 µg/m ³	< 1µg/m ³
DMF (dimethylformamide)	< 1 µg/m ³	<15 µg/m ³
Formaldehyde	2 µg/m ³	</= 60 µg/m ³
R-value	0,04	</= 1
Odour measurement	1,7	</= 3,0