

Report

Product: SOLIDO COLOR T470-xx BN00

Regarding: DIN EN 16516:2020-10
Testing and evaluation of the release of dangerous substances
Determination of emissions into indoor air

Report No: 57621-A003-DGM-L

Results:

| Measurements after 28 days | result | requirement |
|----------------------------|-----------------------|---------------------------|
| TVOC C6-C16 | 17 µg/m ³ | </= 450 µg/m ³ |
| TVOC C16-C22 | < 5 µg/m ³ | </= 100 µg/m ³ |
| CMR substances cat 1A/1B | < 1 µg/m ³ | < 1µg/m ³ |
| DMF (dimethylformamide) | < 1 µg/m ³ | <15 µg/m ³ |
| Formaldehyde | < 2 µg/m ³ | </= 60 µg/m ³ |
| R-value | 0,02 | </= 1 |
| Odour measurement | 3,0 | </= 3,0 |